

BULLETIN NO. 5

TO : **Conventional Builders**
FROM : **Nimesh Patel**
DATE : **February 22, 2019**
PROJECT : **DeIDOT Phase II Renovations**

DESCRIPTION


1. In response to RFI #9 sent on 2/20/2019 Item #3. Refer to attached SK-A.6 for area of brick face.
 - a. Brick face to be provided in areas as shown on attached SK-A.6. In planter area, brick face within the planting area should be provided to at least 2 courses below planter bed.

BASEMENT WELL

DENOTES AREA OF BRICK FACE. IN PLANTERS, PROVIDE BRICK TO 2 COUSES BELOW PLANTING BED

PLANTING BED

PLANTING BED



PLAN @ REAR COURTYARD

SCALE: 1/8"=1'-0"

2/22/2019

DATE

18015

PROJECT NO.

SHEET NO.

SK-A.6

PROJECT: STATE OF DELAWARE
DELAWARE DEPARTMENT OF TRANSPORTATION
OMB/DFM PROJECT # MC5511000018
PHASE II RENOVATION AND OCR COMPLIANCE PROJECT
AT
KENT COUNTY ADMINISTRATION BUILDING
800 BAY ROAD DOVER, DELAWARE 19901



STUDIO JAED
ARCHITECTS ■ ENGINEERS ■ FACILITIES SOLUTIONS

CORPORATE HEADQUARTERS
2500 WRANGLE HILL ROAD, STE. 110
BEAR, DE 19701
P: (302) 832-1802 F: (302) 832-1423
Website: www.studiojaed.com E-Mail: info@studiojaed.com

THIS DOCUMENT IS THE PROPERTY OF STUDIO JAED AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF STUDIO JAED.

REVISIONS: