

Date: April 13, 2022

ASI-05

Project: DeIDOT Georgetown Administration Building

Project No: T202180102

SJ Project No: 20069

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

Revised Drawings

A-102 – DIMENSION FLOOR PLAN

A-110 – REFLECTED CEILING PLAN

1. Moved wall in Conference Room B121, see sketch ASK-04.

A-800 – FINISH SCHEDULE AND FINISH PLAN

1. Revised Schedule
2. Revised Accent colors

ED101 – ELECTRICAL FLOOR DEMOLITION PLAN

1. Added demolition keynote ED-7 to the notes.
2. Changed existing devices on walls in rooms B-130, B-131, and B-133 to be temporarily disconnected and retained.

E-101 – ELECTRICAL POWER PLANS

1. Added new work keynote E – 5 to the notes.
2. Provided existing devices on new walls to be reinstalled.

E-201 – ELECTRICAL LIGHTING PLAN

1. Added new lighting keynote EL-1 to the notes.
2. Provided existing light switches on new walls to be reinstalled.

E-301 – ELECTRICAL FIRE ALARM PLAN

1. Added new fire alarm keynote EF-1 to the notes.
2. Provided existing horn strobe on new wall to be reinstalled.

See revised ED101, E-101, E-201, and E-301 for additional information.