



Gipe Associates, Inc.
CONSULTING ENGINEERS

W.O.#: 20050

November 28, 2022

Mr. Luis Rindfleish, AIA
ABHA Architects
1621 North Lincoln Street
Wilmington, Delaware 19806

Project: Cape Henlopen Middle School
Reference: ASI-014

This ASI forms a part of the contract documents and modified the original bidding documents dated March 18, 2022.

This ASI consists of two (2) pages and the attached revised drawings.

CHANGES TO DRAWINGS:

1. Sheet P-112 – FIRST FLOOR PLAN – AREA ‘B’ – PLUMBING
 - a. ADD: Add new storm drain piping and associated cleanouts, hangers, insulation, etc. as indicated on drawing. These items are related to the new low canopy roof drains being added.

2. Sheet P-142 – ROOF PLAN – AREA ‘B’ – PLUMBING
 - a. ADD: Add new roof drains on low canopy roofs as indicated on drawing.
 - b. ADD: Add new roof drain along column line B.8:B.W as indicated on drawing.
 - c. DELETE: Delete two roof drains (One, shown between SZVAV-1 & SZVAV-2, and Two, shown between KEF-2 & KEF-3). Along with deleted roof drains, delete all associated branch piping, hangers, insulation, etc.)

3. Sheet P-201 – PART PLAN – PLUMBING (Part Plan #1)
 - a. ADD: Add new storm drain piping and associated cleanouts, hangers, insulation, etc. as indicated on drawing. These items are related to the new roof drain near column B.8:B.W.
 - b. DELETE: Delete branch piping, hangers, insulation etc. indicated on drawing. These items are related to the deleted roof drains above the kitchen area.

4. Sheet P-202 – PART PLANS – PLUMBING (Part Plan #1)
 - a. ADD: Add new storm drain piping and associated cleanouts, hangers, insulation, etc. as indicated on drawing.

END OF ASI-014

Enclosures:
P-112, P-142, P-201, & P-202