

SECTION 08 52 00

ALUMINUM CLAD WOOD WINDOWS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes aluminum-clad wood windows.

1.3 ACTION SUBMITTALS

- A. Shop Drawings: Include plans, elevations, sections, hardware, accessories, insect screens, operational clearances, and details of installation, including anchor, flashing, and sealant installation.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An installer acceptable to wood window manufacturer or supplier for installation of units required for this Project.

1.5 WARRANTY

- A. Manufacturer's Warranty: Manufacturer agrees to repair or replace wood windows that fail in materials or workmanship within specified warranty period.

- 1. Failures include, but are not limited to, the following:

- a. Failure to meet performance requirements.
- b. Structural failures including excessive deflection, water leakage, and air infiltration.
- c. Faulty operation of movable sash and hardware.
- d. Deterioration of materials and finishes beyond normal weathering.
- e. Failure of insulating glass.

- 2. Warranty Period:

- a. Window: 10 years from date of Substantial Completion.
- b. Glazing Units, Laminated: 10 years from date of Substantial Completion.
- c. Aluminum-Cladding Finish: 10 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide Pella Corporation Architect Series® or comparable product by one of the following:
 - 1. Aluminum-Clad Wood Windows:
 - a. Marvin Windows and Doors.
 - b. Approved equal.
- B. Source Limitations: Obtain windows from single source from single manufacturer.

2.2 WINDOW PERFORMANCE REQUIREMENTS

- A. Product Standard: Comply with AAMA/WDMA/CSA 101/I.S.2/A440 for definitions and minimum standards of performance, materials, components, accessories, and fabrication unless more stringent requirements are indicated.
- B. Performance Class: AAMA/WDMA/CSA 101/I.S.2/A440 as follows:
 - 1. Minimum Performance Class: CW.
- C. Thermal Transmittance: NFRC 100 maximum whole-window U-factor of 0.29 Btu/sq. ft. x h x deg F .
- D. Solar Heat-Gain Coefficient (SHGC): NFRC 200 maximum whole-window SHGC of 0.25.
- E. Outside-Inside Transmission Class (OITC): Rated for not less than 26 OITC when tested for laboratory sound transmission loss according to ASTM E 90 and determined by ASTM E 1332.
- F. Sound Transmission Class (STC): Rated for not less than 30 STC when tested for laboratory sound transmission loss according to ASTM E 90 and determined by ASTM E 413.
- G. The minimum U-value: .29.
- H. Meet Energy Star requirements.

2.3 WOOD WINDOWS

- A. Operating Types: Provide the following operating types in locations indicated on Drawings:
 - 1. Single Hung
- B. Frames and Sashes: Fine-grained wood lumber complying with AAMA/WDMA/CSA 101/I.S.2/A440; kiln dried to a moisture content of not more than 12 percent at time of fabrication; free of visible finger joints, blue stain, knots, pitch pockets, and

surface checks larger than 1/32 inch (0.8 mm) deep by 2 inches (51 mm) wide; water-repellent preservative treated.

1. Exterior Finish: Aluminum-clad wood.
 - a. Aluminum Finish: Manufacturer's standard baked-on enamel finish.
 - b. Color: White.
 2. Interior Finish: Manufacturer's standard factory-prime coat.
 - a. Painted Color: White.
- C. Insulating-Glass Units: ASTM E 2190, certified through IGCC as complying with requirements of IGCC.
1. Glass: ASTM C 1036, Type 1, Class 1, q3.
 2. Filling: Fill space between glass lites with argon.
 3. Low-E Coating: Sputtered on second or third surface.
- D. Hardware, General: Provide manufacturer's standard hardware fabricated from aluminum, stainless steel, carbon steel complying with AAMA 907, or other corrosion-resistant material compatible with adjacent materials; designed to smoothly operate, tightly close, and securely lock windows, and sized to accommodate sash weight and dimensions.
1. Exposed Hardware Color and Finish: White.
- E. Weather Stripping: Provide full-perimeter weather stripping for each operable sash unless otherwise indicated.
- F. Fasteners: Noncorrosive and compatible with window members, trim, hardware, anchors, and other components.
1. Exposed Fasteners: Do not use exposed fasteners to the greatest extent possible. For application of hardware, use fasteners that match finish hardware being fastened.
- 2.4 FABRICATION
- A. Fabricate wood windows in sizes indicated. Include a complete system for installing and anchoring windows.
 - B. Glaze wood windows in the factory.
 - C. Weather strip each operable sash to provide weathertight installation.
 - D. Complete fabrication, assembly, finishing, hardware application, and other work in the factory to greatest extent possible. Disassemble components only as necessary for shipment and installation. Allow for scribing, trimming, and fitting at Project site.

2.5 ACCESSORIES

- A. Dividers: Provide divider grilles for each sash lite.
 - 1. Located between insulating glass.
 - 2. Type: $\frac{3}{4}$ inch contour, traditional.
 - 3. Color: White.
 - 4. See drawings for pattern.
- B. Window Screen:
 - 1. Charcoal fiberglass mesh.
 - 2. Screen surround: Stone white.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine openings, substrates, structural support, anchorage, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Verify rough opening dimensions, levelness of sill plate, and operational clearances.
- C. Examine wall flashings, vapor retarders, water and weather barriers, and other built-in components to ensure weathertight window installation.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Comply with manufacturer's written instructions for installing windows, hardware, accessories, and other components. For installation procedures and requirements not addressed in manufacturer's written instructions, comply with installation requirements in ASTM E 2112.
- B. Install windows level, plumb, square, true to line, without distortion, anchored securely in place to structural support, and in proper relation to wall flashing and other adjacent construction to produce weathertight construction.
- C. Separate aluminum and other corrodible surfaces from sources of corrosion or electrolytic action. (dissimilar materials, treated lumber, etc.) at the points of contact with other materials.
- D. For fin method of attachment, integrate window system installation with exterior water-resistant barrier using flashing/sealant tape. Apply and integrate flashing/sealant tape with water-resistant barrier using watershed principles in accordance with window manufacturer's instructions.
- E. Place interior seal around window perimeter to maintain continuity of building thermal and air barrier using insulating-foam sealant.

- F. Seal window to exterior wall cladding with sealant and related backing materials at perimeter of assembly.
- G. Leave windows closed and locked.

3.3 ADJUSTING, CLEANING, AND PROTECTION

- A. Adjust operating sashes and hardware for a tight fit at contact points and weather stripping for smooth operation and weathertight closure.
- B. Clean exposed surfaces immediately after installing windows. Remove excess sealants, glazing materials, dirt, and other substances.
 - 1. Keep protective films and coverings in place until final cleaning.
- C. Remove and replace sashes if glass has been broken, chipped, cracked, abraded, or damaged during construction period.
- D. Protect window surfaces from contact with contaminating substances resulting from construction operations. If contaminating substances do contact window surfaces, remove contaminants immediately according to manufacturer's written instructions.

END OF SECTION

This page intentionally left blank.