

DELAWARE OFFICE:

2500 WRANGLE HILL ROAD
FOX RUN OFFICE PLAZA, SUITE 110
BEAR, DE 19701

302.832.1652 **PHONE**

302.832.1423 **FAX**

ARCHITECTS

ENGINEERS

FACILITIES SOLUTIONS

ASI No. 2 – MAU Demolition

TO : Conventional Builders

FROM : Dan Shurina

DATE : 01/12/2024

REFERENCE : 19121 East Wing HVAC Replacement at DelDOT Admin Bldg

Changes to Scope:

1. Add demolition of existing combustion air makeup air unit at lower level hot water pump room adjacent to loading dock.
 - a. Demolish and remove from site the makeup air unit and all associated ductwork, hangers, piping and controls.
 - b. Demolish electrical circuit back to source panel. Retain breaker and label panel.
 - c. Demolish motorized damper at associated wall louver which is to remain.
 - d. Provide weatherproof insulated metal panel at interior louver face having minimum 2” rigid insulation.

END