

DELAWARE OFFICE:

2500 WRANGLE HILL ROAD
FOX RUN OFFICE PLAZA, SUITE 110
BEAR, DE 19701

302.832.1652 **PHONE**

302.832.1423 **FAX**

ARCHITECTS

ENGINEERS

FACILITIES SOLUTIONS

ASI No. 10 – Area Temperature Display

TO : Conventional Builders

FROM : Dan Shurina

DATE : 01/31/24

REFERENCE : 19121 East Wing HVAC Replacement at DeIDOT Admin Bldg

Changes to Scope:

1. Provide four (4) wall-mounted temperature display with override button. Each temperature input shall be an average of all new zone temperature feedback within the noted area. The temperature shall not be adjustable or sensed from these displays but related zones are to be overridden to occupied mode when the occupancy override button is pressed from a temperature display.
2. See attached HVAC drawings with marked up notations.

END

