

## SECTION 22 13 19

### SANITARY WASTE PIPING SPECIALTIES

#### PART 1 - GENERAL

##### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

##### 1.2 SUMMARY

- A. Section Includes:
  - 1. Cleanouts.

##### 1.3 DEFINITIONS

- A. ABS: Acrylonitrile butadiene styrene.
- B. PVC: Polyvinyl chloride.

##### 1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

#### PART 2 - PRODUCTS

##### 2.1 ASSEMBLY DESCRIPTIONS

- A. Sanitary waste piping specialties shall bear label, stamp, or other markings of specified testing agency.
- B. Comply with NSF 14 for plastic sanitary waste piping specialty components.

##### 2.2 CLEANOUTS

- A. Cast-Iron Exposed Floor Cleanouts :
  - 1. Standard: ASME A112.36.2M for adjustable housing cleanout.
  - 2. Size: Same as connected branch.
  - 3. Type: Threaded, adjustable housing.

4. Body or Ferrule: Cast iron.
5. Clamping Device: Required.
6. Outlet Connection: Threaded.
7. Closure: Cast-iron plug .
8. Adjustable Housing Material: Cast iron with threads .
9. Frame and Cover Material and Finish: Nickel-bronze, copper alloy .
10. Frame and Cover Shape: Round or Square .
11. Top-Loading Classification: Heavy Duty.
12. Riser: ASTM A74, Service Class, cast-iron drainage pipe fitting and riser to cleanout.

B. Cast-Iron Wall Cleanouts :

1. Standard: ASME A112.36.2M. Include wall access.
2. Size: Same as connected drainage piping.
3. Body: Hub-and-spigot, cast-iron soil pipe T-branch as required to match connected piping.
4. Closure Plug:
  - a. Brass .
  - b. Countersunk head.
  - c. Drilled and threaded for cover attachment screw.
  - d. Size: Same as or not more than one size smaller than cleanout size.
5. Wall Access, Cover Plate: Round, deep, chrome-plated bronze cover plate with screw.
6. Wall Access, Frame and Cover: Square , nickel-bronze, copper-alloy, or stainless steel wall-installation frame and cover.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Install cleanouts in aboveground piping and building drain piping according to the following, unless otherwise indicated:
  1. Size same as drainage piping up to NPS 4. Use NPS 4 for larger drainage piping unless larger cleanout is indicated.
  2. Locate at each change in direction of piping greater than 45 degrees.
  3. Locate at minimum intervals of 50 feet for piping NPS 4 and smaller and 100 feet for larger piping.
  4. Locate at base of each vertical soil and waste stack.
- B. For floor cleanouts for piping below floors, install cleanout deck plates with top flush with finished floor.
- C. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- D. Install sleeve and sleeve seals with each riser and stack passing through floors with waterproof membrane.

- E. Install expansion joints on vertical stacks and conductors. Position expansion joints for easy access and maintenance.
- F. Install wood-blocking reinforcement for wall-mounting-type specialties.
- G. Install traps on plumbing specialty drain outlets. Omit traps on indirect wastes unless trap is indicated.

### 3.2 PIPING CONNECTIONS

- A. Comply with requirements in Section 22 13 16 "Sanitary Waste and Vent Piping" for piping installation requirements. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment, to allow service and maintenance.

### 3.3 LABELING AND IDENTIFYING

- A. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit.
  - 1. Nameplates and signs are specified in Section 22 05 53 "Identification for Plumbing Piping and Equipment."

### 3.4 PROTECTION

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

END OF SECTION 22 13 19

This page intentionally left blank.