

SECTION 22 47 13
DRINKING FOUNTAINS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Drinking fountains.
 - 2. Bottle filling stations.
 - 3. Supports.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of drinking fountain and bottle filling station.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
 - 2. Include operating characteristics, and furnished specialties and accessories.

1.4 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For drinking fountains and bottle filling stations to include in maintenance manuals.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Standards:
 - 1. Drinking fountains and bottle filling stations intended to convey or dispense water for human consumption are to comply with the U.S. Safe Drinking Water Act (SDWA), requirements of the Authority Having Jurisdiction (AHJ), and with NSF 61 or NSF 372, or be certified in compliance with NSF 61 or NSF 372 by an ANSI-accredited third-party certification body, that the weighted average lead content at wetted surfaces is less than or equal to 0.25 percent.

2. Comply with ASME A112.19.3/CSA B45.4 for stainless steel drinking fountains and bottle filling stations.
3. Comply with NSF 42 and NSF 53 for water filters for drinking fountains and bottle filling stations.
4. Comply with ICC A117.1 for accessible drinking fountains and bottle filling stations.

2.2 DRINKING FOUNTAINS

A. Drinking Fountains - Surface Wall-Mounted, Stainless Steel: .

1. Source Limitations: Obtain surface wall-mounted, stainless steel drinking fountains from single source from single manufacturer.
2. Receptor(s):
 - a. Type: On horizontal support.
 - b. Shape: Rectangular .
 - c. Back Panel: Stainless steel wall plate behind drinking fountain.
 - d. Bubblers: One for each receptor, with adjustable stream regulator, located on deck.
 - e. Drain: Grid type with NPS 1-1/4 tailpiece.
3. Maximum Water Flow: 0.15 gpm .
4. Control: Push bar .
5. Supply: NPS 3/8 with shutoff valve.
6. Waste Fitting: ASME A112.18.2/CSA B125.2, NPS 1-1/4 chrome-plated brass P-trap and waste.
7. Filter: One or more water filters with capacity sized for unit peak flow rate.
8. Electrical Characteristics:
 - a. Volts: 120 V ac.
 - b. Phase: Single.
 - c. Hertz: 60 Hz.
9. Support: Provide manufacturer's mounting plate and drinking fountain carrier .
10. Drinking Fountain Mounting Height: High/low - standard/accessible in accordance with ICC A117.1.
11. Freeze-Resistant Supply Fittings: Through wall freeze-resistant shutoff and flow-control valve assembly.

2.3 BOTTLE FILLING STATIONS

A. Bottle Filling Station - Surface Wall-Mounted, Stainless Steel: .

1. Source Limitations: Obtain surface wall-mounted, stainless steel, bottle filling stations from single source from single manufacturer.
2. Cabinet: Stainless steel.
3. Bottle Filler: Sensor activation , with 20-second automatic shutoff timer. Fill rate 0.5 to 1.5 gpm .
4. Drain: Grid type with NPS 1-1/4 tailpiece.
5. Supply: NPS 3/8 with shutoff valve.
6. Waste Fitting: ASME A112.18.2/CSA B125.2, NPS 1-1/4 brass P-trap.
7. Filter: One or more water filters complying with NSF 42 and NSF 53 and with capacity sized for peak flow rate.
8. Support: Provide manufacturer's mounting plate and drinking fountain carrier .

9. Bottle Filling Station Mounting Height: Standard .
10. Electrical Characteristics:
 - a. Volts: 120 V ac.
 - b. Phase: Single.
 - c. Hertz: 60 Hz.

2.4 SUPPORTS

- A. Drinking Fountain Carrier:
 1. Standard: ASME A112.6.1M.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in for water-supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before fixture installation.
- B. Examine walls and floors for suitable conditions where fixtures will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install fixtures level and plumb according to roughing-in drawings. For fixtures indicated for children, install at height required by authorities having jurisdiction.
- B. Set pedestal drinking fountains and bottle filling stations on flat surface in accordance with manufacturer's written installation instructions.
- C. Install recessed, drinking fountains and bottle filling stations secured to wood blocking in wall construction.
- D. Install off-the-floor carrier supports, affixed to building substrate, for wall-mounted fixtures.
- E. Install water-supply piping with shutoff valve on supply to each fixture to be connected to domestic-water distribution piping. Use ball valve. Install valves in locations where they can be easily reached for operation. Valves are specified in Section 22 05 23.12 "Ball Valves for Plumbing Piping"
- F. Install trap and waste piping on drain outlet of each fixture to be connected to sanitary drainage system.
- G. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons where required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 22 05 00 "Common Work Results for Plumbing."

- H. Seal joints between fixtures and walls using sanitary-type, one-part, mildew-resistant, silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 07 92 00 "Joint Sealants."

3.3 PIPING CONNECTIONS

- A. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.
- B. Comply with water piping requirements specified in Section 22 11 16 "Domestic Water Piping."
- C. Install ball shutoff valve on water supply to each fixture. Install valve upstream from filter for drinking fountain. Comply with valve requirements specified in Section 22 05 23.12 "Ball Valves for Plumbing Piping"
- D. Comply with soil and waste piping requirements specified in Section 22 13 16 "Sanitary Waste and Vent Piping."

3.4 ELECTRICAL CONNECTIONS

- A. Ground equipment according to Section 26 05 26 "Grounding and Bonding for Electrical Systems."
- B. Install electrical devices furnished by manufacturer, but not factory mounted, according to NFPA 70 and NECA 1.
- C. Install nameplate for each electrical connection, indicating electrical equipment designation and circuit number feeding connection.
 - 1. Nameplates to be laminated acrylic or melamine plastic signs, as specified in Section 26 05 53 "Identification for Electrical Systems."

3.5 ADJUSTING

- A. Adjust fixture flow regulators for proper flow and stream height.

END OF SECTION 22 47 13