

SECTION 22 05 17

SLEEVES AND SLEEVE SEALS FOR PLUMBING PIPING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Sleeves without waterstop.
2. Sleeves with waterstop.
3. Silicone sealants.

1.2 ACTION SUBMITTALS

- ###### A. Product Data:
- For each type of product.

PART 2 - PRODUCTS

2.1 SLEEVES WITHOUT WATERSTOP

- ###### A. Steel Pipe Sleeves:
- ASTM A53/A53M, Type E, Grade B, Schedule 40, hot-dip galvanized, with plain ends.

2.2 SLEEVES WITH WATERSTOP

- ###### A. Description:
- Manufactured PVC/HDPE, steel, sleeve-type, waterstop assembly made for imbedding in concrete slab or wall.

2.3 SILICONE SEALANTS

- ###### A. Silicone, S, NS, 25, NT:
- Single-component, nonsag, plus 25 percent and minus 25 percent movement capability, nontraffic-use, neutral-curing silicone joint sealant.
1. Standard: ASTM C920, Type S, Grade NS, Class 25, Use NT.

PART 3 - EXECUTION

3.1 INSTALLATION OF SLEEVES - GENERAL

- ###### A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.

- B. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
 - 1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
 - 2. Cut sleeves to length for mounting flush with both surfaces.
 - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level.
 - 3. Using silicone sealant, seal the space outside of sleeves in slabs and walls without sleeve-seal system.
- C. Install sleeves for pipes passing through interior partitions.
 - 1. Cut sleeves to length for mounting flush with both surfaces.
 - 2. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.
 - 3. Seal annular space between sleeve and piping or piping insulation; use joint sealants appropriate for size, depth, and location of joint.
- D. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping and fill materials specified in Section 07 84 13 "Penetration Firestopping."

3.2 INSTALLATION OF SLEEVES WITH WATERSTOP

- A. Install sleeve with waterstop as new walls and slabs are constructed.
- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange to be centered in concrete slab or wall.
- C. Secure nailing flanges to concrete forms.
- D. Using silicone sealant, seal the space around outside of sleeves.

3.3 SLEEVE SCHEDULE

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
 - 1. Interior Partitions:
 - a. Sleeves without waterstops.

END OF SECTION 22 05 17