

SECTION 26 05 43

UNDERGROUND DUCTS AND RACEWAYS FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Type IMC raceways.
2. Type PVC raceways and fittings.
3. Fittings for conduit, tubing, and cable.
4. Electrically conductive corrosion-resistant compounds for threaded conduit.

B. Related Requirements:

1. Section 26 05 19 "Low-Voltage for Electrical Power Conductors and Cables" for nonmetallic underground conduit with conductors (Type NUCC).

1.2 DEFINITIONS

- A. Duct: A single raceway or multiple raceways, installed singly or as components of a duct bank.
- B. Duct Bank: Two or more ducts installed in parallel, direct buried or with additional casing materials such as concrete.
- C. Handhole: An underground chamber containing electrical cables, sized such that personnel are not required to enter in order to access the cables.
- D. Manhole: An underground chamber containing electrical cables and equipment, sized to provide access with working space clearances.
- E. Trafficways: Locations where vehicular or pedestrian traffic is a normal course of events.

1.3 ACTION SUBMITTALS

A. Product Data:

1. Type IMC raceways.
2. Type PVC raceways and fittings.

PART 2 - PRODUCTS

2.1 TYPE IMC RACEWAYS

A. Performance Criteria:

1. Regulatory Requirements: Listed and labeled in accordance with NFPA 70 and marked for intended location and use.
2. General Characteristics: UL 1242 and UL CCN DYBY.

B. Steel Electrical Intermediate Metal Conduit (IMC):

1. Options:
 - a. Exterior Coating: Zinc .
 - b. Interior Coating: Zinc with organic top coating Zinc .
 - c. Minimum Trade Size: Metric designator 21 (trade size 3/4).
 - d. Colors: As indicated on Drawings.

2.2 TYPE PVC RACEWAYS AND FITTINGS

A. Performance Criteria:

1. Regulatory Requirements: Listed and labeled in accordance with NFPA 70 and marked for intended location and use.
2. General Characteristics: UL 651 and UL CCN DZYR.

B. Schedule 40 Rigid PVC Conduit (PVC-40) and Fittings:

1. Dimensional Specifications: Schedule 40.
2. Options:
 - a. Minimum Trade Size: Metric designator 21 (trade size 3/4).
 - b. Markings: For use with maximum 90 deg C wire.

C. Type EB Rigid PVC Concrete-Encased Underground Conduit (PVC-EB) and Fittings:

1. Dimensional Specifications: Type EB.
2. Options:
 - a. Minimum Trade Size: Metric designator 53 (trade size 2) .

2.3 FITTINGS FOR CONDUIT, TUBING, AND CABLE

A. Performance Criteria:

1. Regulatory Requirements: Listed and labeled in accordance with NFPA 70 and marked for intended location and use.

B. Metallic Fittings for Type ERM, Type IMC, Type PVC, Type EPEC, and Type RTRC Raceways:

1. General Characteristics: UL 514B and UL CCN DWTT.
2. Options:
 - a. Material: Steel .
 - b. Coupling Method: Compression coupling Raintight compression coupling with distinctive color gland nut Setscrew coupling. Setscrew couplings with only single screw per conduit are unacceptable.
 - c. Conduit Fittings for Hazardous (Classified) Locations: UL 1203.
 - d. Expansion and Deflection Fittings: UL 651 with flexible external bonding jumper.

2.4 ELECTRICALLY CONDUCTIVE CORROSION-RESISTANT COMPOUNDS FOR THREADED CONDUIT

A. Performance Criteria:

1. Regulatory Requirements: Listed and labeled in accordance with NFPA 70 and marked for intended location and use.
2. General Characteristics: UL Subject 2419 and UL CCN FOIZ.

2.5 MANHOLES FOR EXTERIOR UNDERGROUND WIRING

A. Performance Criteria:

1. Regulatory Requirements: Listed and labeled in accordance with NFPA 70 and marked for intended location and use.
2. General Characteristics:
 - a. ASTM C858 for design and manufacturing processes.
 - b. SCTE 77.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Coordinate layout and installation of duct, duct bank, manholes, handholes, and boxes with final arrangement of other utilities, site grading, and surface features as determined in field. Notify Architect if there is conflict between areas of excavation and existing structures or archaeological sites to remain.
- B. Coordinate elevations of duct and duct-bank entrances into manholes, handholes, and boxes with final locations and profiles of duct and duct banks, as determined by coordination with other utilities, underground obstructions, and surface features. Revise locations and elevations as required to suit field conditions and to ensure that duct and duct bank will drain to manholes and handholes, and as approved by Architect.

- C. Clear and grub vegetation to be removed, and protect vegetation to remain in accordance with Section 31 10 00 "Site Clearing." Remove and stockpile topsoil for reapplication in accordance with Section 31 10 00 "Site Clearing."

3.2 SELECTION OF UNDERGROUND DUCTS

- A. Duct for Electrical Feeders 600 V and Less: PVC-40 , concrete encased unless otherwise indicated.
- B. Duct for Electrical Branch Circuits: PVC-40 , direct buried unless otherwise indicated.
- C. Bored Underground Duct: EPEC-40 unless otherwise indicated.
- D. Stub-ups: Concrete encased, PVC-40 IMC.

3.3 EARTHWORK

- A. Excavation and Backfill: Comply with Section 31 20 00 "Earth Moving," but do not use heavy-duty, hydraulic-operated, compaction equipment.
- B. Restoration: Restore area immediately after backfilling is completed .
- C. Restore surface features at areas disturbed by excavation, and re-establish original grades unless otherwise indicated. Replace removed sod immediately after backfilling is completed.
- D. Restore areas disturbed by trenching, storing of dirt, cable laying, and other work. Restore vegetation and include necessary topsoiling, fertilizing, liming, seeding, sodding, sprigging, and mulching. Comply with Section 32 92 00 "Turf and Grasses" and Section 32 93 00 "Plants."
- E. Cut and patch existing pavement in path of underground duct, duct bank, and underground structures in accordance with "Cutting and Patching" Article in Section 01 73 00 "Execution."

3.4 INSTALLATION OF DUCTS AND DUCT BANKS

- A. Reference Standards:
 - 1. Unless more stringent requirements are specified in Contract Documents or manufacturers' published instructions, comply with NEMA TCB 2 for installation of underground ducts and duct banks.
 - 2. Consult Architect for resolution of conflicting requirements.
- B. Special Techniques:
 - 1. Where indicated on Drawings, install duct, spacers, and accessories into duct-bank configuration shown. Duct installation requirements in this Section also apply to duct bank.
 - 2. Steel raceway, bends, and fittings in single duct run or duct bank must be of same type.

3. Slope: Pitch duct minimum slope of 1:300 down toward manholes and handholes and away from buildings and equipment. Slope duct from high point between two manholes to drain in both directions.
4. Expansion and Deflection Fittings: Install expansion and deflection fitting in each duct in area of disturbed earth adjacent to manhole or handhole.
5. Install expansion fitting near center of straight line duct with calculated expansion of more than 3/4 inch.
6. Curves and Bends:
 - a. Use 5-degree angle couplings for small changes in direction. Use manufactured long sweep bends with minimum radius of 48 inch , both horizontally and vertically, at other locations unless otherwise indicated.
 - b. Field bending must be in accordance with NFPA 70 minimum radii requirements, except bends over 45 degrees must be made with minimum radius of 48 inch . Use only equipment specifically designed for material and size involved. Use PVC heating bender for bending PVC conduit.
 - c. Duct must have maximum of 180 degrees of bends between pull points.
7. Joints: Use solvent-cemented joints in nonmetallic duct and fittings and make watertight in accordance with manufacturer's published instructions. Stagger couplings so those of adjacent duct do not lie in same plane. Couple steel conduits to ducts with adapters designed for this purpose, and encase coupling with minimum 3 inch of concrete for minimum of 12 inch on each side of coupling.
 - a. Install insulated grounding bushings on steel raceway terminations that are less than 12 inch below grade or floor level and do not terminate in hubs.
8. Installation Adjacent to High-Temperature Steam Lines: Where duct is installed parallel to underground steam lines, perform calculations showing duct will not be subject to environmental temperatures above 104 deg F. Where environmental temperatures are calculated to rise above 104 deg F, and anywhere duct crosses above underground steam line, install insulation blankets listed for direct burial to isolate duct bank from steam line to maintain maximum environmental temperature of 104 deg F.
9. End Bell Entrances to Manholes and Concrete and Polymer Concrete Handholes: Use end bells, spaced approximately 10 inch o.c. for 5 inch duct, and vary proportionately for other duct sizes.
 - a. Begin change from regular spacing to end-bell spacing 10 ft from end bell, without reducing duct slope and without forming trap in line.
 - b. Grout end bells into structure walls from both sides to provide watertight entrances.
10. Duct Terminators for Entrances to Cast-in-Place Manholes and Concrete Handholes: Use manufactured, cast-in-place duct terminators, with entrances into structure spaced approximately 6 inch o.c. for 4 inch duct, and vary proportionately for other duct sizes.
 - a. Begin change from regular spacing to terminator spacing 10 ft from terminator, without reducing duct line slope and without forming trap in line.
11. Building Wall Penetrations: Make transition from underground duct to steel raceway at least 10 ft outside building wall, without reducing duct line slope away from building and without forming trap in line. Use fittings manufactured for transition to steel raceway type installed. Install steel raceway penetrations of building walls as specified in Section 26 05 44 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."
12. Install manufactured steel raceway elbows for stub-ups at poles unless otherwise indicated. Encase elbows for stub-up ducts throughout length of elbow.

- a. Couple steel elbows to ducts with adapters designed for this purpose, and encase coupling with minimum 3 inch of concrete for minimum of 12 inch on each side of coupling.
13. Sealing: Provide temporary closure at terminations of duct with pulled cables. Seal spare duct at terminations. Use sealing compound and plugs to withstand at least 15 psig hydrostatic pressure.
14. Pulling Cord: Install 200 lbf test nylon cord in empty ducts.
15. Concrete-Encased Ducts and Duct Bank:
 - a. Excavate trench bottom to provide firm and uniform support for duct. Prepare trench bottoms as specified in Section 31 20 00 "Earth Moving" for pipes 6 inch or less in nominal diameter.
 - b. Width: Excavate trench 3 inch wider than duct on each side.
 - c. Depth: Install so top of duct envelope is at least 24 inch below finished grade in areas not subject to deliberate traffic, and at least 30 inch below finished grade in deliberate traffic paths for vehicles unless otherwise indicated. Install so top of duct envelope is below local frost line.
 - d. Support duct on duct spacers coordinated with duct size, duct spacing, and outdoor temperature.
 - e. Spacer Installation: Place spacers close enough to prevent sagging and deforming of duct, with not less than four spacers per 20 ft of duct. Place spacers within 24 inch of duct ends. Stagger spacers approximately 6 inch between tiers. Secure spacers to earth and to duct to prevent floating during concreting. Tie entire assembly together using fabric straps; do not use tie wires or reinforcing steel that may form conductive or magnetic loops around ducts or duct groups.
 - f. Minimum Space between Ducts: 3 inch between edge of duct and exterior envelope wall, 2 inch between ducts for like services, and 4 inch between power and communications ducts.
 - g. Elbows:
 - 1) Use manufactured duct elbows for stub-ups and at changes of direction in duct unless otherwise indicated. Extend encasement throughout length of elbow.
 - 2) Use manufactured steel elbows for stub-ups, at building entrances, and at changes of direction in duct run.
 - h. Stub-ups to Outdoor Equipment: Extend concrete-encased steel raceway horizontally minimum of 60 inch from edge of equipment base.
 - 1) Stub-ups must be minimum 4 inch above finished floor and minimum 3 inch from conduit side to edge of slab.
 - i. Stub-ups to Indoor Equipment: Extend concrete-encased steel raceway horizontally minimum of 60 inch from edge of wall. Install insulated grounding bushings on terminations at equipment.
 - 1) Stub-ups must terminate in coupling installed flush with be minimum 4 inch above finished floor and no less than 3 inch from conduit side to edge of slab.
 - j. Reinforcement: Reinforce concrete-encased duct where crossing disturbed earth and where indicated. Arrange reinforcing rods and ties without forming conductive or magnetic loops around ducts or duct groups.
 - k. Forms: Use walls of trench to form side walls of duct bank where soil is self-supporting and concrete envelope can be poured without soil inclusions; otherwise, use forms.

- l. Concrete Cover: Install minimum of 3 inch of concrete cover between edge of duct to exterior envelope wall, 2 inch between duct of like services, and 4 inch between power and communications ducts.
 - m. Place minimum 6 inch of engineered fill above concrete encasement of duct.
 - n. Concreting Sequence: Pour each run of envelope between manholes or other terminations in one continuous operation.
 - 1) Start at one end and finish at other, allowing for expansion and contraction of duct as its temperature changes during and after pour. Use expansion fittings installed in accordance with manufacturer's published instructions, or use other specific measures to prevent expansion-contraction damage.
 - 2) If more than one pour is necessary, terminate each pour in vertical plane and install 3/4 inch reinforcing-rod dowels extending minimum of 18 inch into concrete on both sides of joint near corners of envelope.
 - o. Pouring Concrete: Comply with requirements in "Concrete Placement" Article in Section 03 30 00 "Cast-in-Place Concrete." Place concrete carefully during pours to prevent voids under and between duct and at exterior surface of envelope. Do not allow heavy mass of concrete to fall directly onto ducts. Allow concrete to flow around duct and rise up in middle, uniformly filling open spaces. Do not use power-driven agitating equipment unless specifically designed for duct-installation application.
16. Direct-Buried Duct and Duct Bank:
- a. Excavate trench bottom to provide firm and uniform support for duct. Comply with requirements in Section 31 20 00 "Earth Moving" for preparation of trench bottoms for pipes less than 6 inch in nominal diameter.
 - b. Width: Excavate trench 3 inch wider than duct on each side.
 - c. Depth: Install top of duct at least 36 inch below finished grade unless otherwise indicated.
 - d. Set elevation of top of duct bank below frost line.
 - e. Place minimum 3 inch of sand as bed for duct. Place sand to minimum of 6 inch above top level of duct.
 - f. Support ducts on duct spacers coordinated with duct size, duct spacing, and outdoor temperature.
 - g. Spacer Installation: Place spacers close enough to prevent sagging and deforming of duct, with not less than four spacers per 20 ft of duct. Place spacers within 24 inch of duct ends. Stagger spacers approximately 6 inch between tiers. Secure spacers to earth and to ducts to prevent floating during concreting. Tie entire assembly together using fabric straps; do not use tie wires or reinforcing steel that may form conductive or magnetic loops around ducts or duct groups.
 - h. Install duct with minimum of 3 inch between ducts for like services and 6 inch between power and communications duct.
 - i. Install manufactured duct elbows for stub-ups, at building entrances, and at changes of direction in duct direction unless otherwise indicated. Encase elbows for stub-up ducts throughout length of elbow.
 - j. Install manufactured steel elbows for stub-ups, at building entrances, and at changes of direction in duct.
 - 1) Couple RNC duct to steel raceway with adapters designed for this purpose, and encase coupling with minimum 3 inch of concrete.

- 2) Stub-ups to Outdoor Equipment: Extend concrete-encased steel raceway horizontally minimum of 60 inch from edge of base. Install insulated grounding bushings on terminations at equipment.
 - a) Stub-ups must be minimum 4 inch above finished base and minimum 3 inch from conduit side to edge of base.
- 3) Stub-ups to Indoor Equipment: Extend concrete-encased steel raceway horizontally on exterior of wall minimum of 60 inch from edge of wall. Install insulated grounding bushings on terminations at equipment.
- 4) Stub-ups through interior floors must be minimum 4 inch above finished floor and no less than 3 inch from conduit side to edge of equipment pad or floor slab.
- k. After installing first tier of duct, backfill and compact. Start at tie-in point and work toward end of duct run, leaving ducts at end of run free to move with expansion and contraction as temperature changes during this process. Repeat procedure after placing each tier. After placing last tier, hand place backfill to 4 inch over duct and hand tamp. Firmly tamp backfill around ducts to provide maximum supporting strength. Use hand tamper only. After placing controlled backfill over final tier, make final duct connections at end of run and complete backfilling with normal compaction. Comply with requirements in Section 31 20 00 "Earth Moving" for installation of backfill materials.
17. Warning Planks: Bury warning planks approximately 12 inch above direct-buried duct, placing them 36 inch o.c. Align planks along width and along centerline of duct or duct bank. Provide additional plank for each 12 inch increment of duct-bank width over nominal 18 inch. Space additional planks 12 inch apart, horizontally across width of ducts.
18. Underground-Line Warning Tape: Bury conducting underground line specified in Section 26 05 53 "Identification for Electrical Systems" no less than 12 inch above concrete-encased duct and duct banks and approximately 12 inch below grade. Align tape parallel to and within 3 inch of centerline of duct bank. Provide additional warning tape for each 12 inch increment of duct-bank width over nominal 18 inch. Space additional tapes 12 inch apart, horizontally across width of ducts.
19. Ground ducts and duct banks in accordance with Section 26 05 26 "Grounding and Bonding for Electrical Systems."

3.5 INSTALLATION OF CONCRETE MANHOLES, HANDHOLES, AND BOXES

A. Reference Standards:

1. Precast Concrete Handholes: Comply with ASTM C891 unless otherwise indicated.
2. Consult Architect for resolution of conflicting requirements.

B. Special Techniques:

1. Cast-in-Place Manholes:
 - a. Finish interior surfaces with smooth-troweled finish.
 - b. Knockouts for Future Duct Connections: Form and pour concrete knockout panels 1-1/2 to 2 inch thick, arranged as indicated.
 - c. Comply with requirements in Section 03 30 00 "Cast-in-Place Concrete" for cast-in-place concrete, formwork, and reinforcement.

2. Precast Concrete Handholes and Manholes:
 - a. Install units level and plumb and with orientation and depth coordinated with connecting duct to minimize bends and deflections required for proper entrances.
 - b. Unless otherwise indicated, support units on level bed of crushed stone or gravel graded from 1 inch sieve to No. 4 sieve and compacted to same density as adjacent undisturbed earth.
 - c. Field-cut openings for conduits in accordance with enclosure manufacturer's published instructions. Cut wall of enclosure with tool designed for material to be cut. Size holes for terminating fittings to be used, and seal around penetrations after fittings are installed.
3. Drainage: Install drains in bottom of manholes where indicated. Coordinate with drainage provisions indicated.

3.6 INSTALLATION OF HANDHOLES AND BOXES OTHER THAN PRECAST CONCRETE

A. Special Techniques:

1. Install handholes and boxes level and plumb and with orientation and depth coordinated with connecting duct, to minimize bends and deflections required for proper entrances. Use box extension if required to match depths of duct, and seal joint between box and extension as recommended by manufacturer.
2. Unless otherwise indicated, support units on level bed of crushed stone or gravel, graded from 1/2 inch sieve to No. 4 sieve and compacted to same density as adjacent undisturbed earth.
3. Elevation: In paved areas and trafficways, set cover flush with finished grade. Set covers of other handholes 1 inch above finished grade.
4. Ground handholes and boxes in accordance with Section 26 05 26 "Grounding and Bonding for Electrical Systems."

END OF SECTION 26 05 43