



February 6, 2025

DNREC Division of Fish and Wildlife  
Attn.: Amanda Delayo, Bayshore Conservation Planner  
89 Kings Highway  
Dover, DE 19901

RE: Assawoman Wildlife Area  
Viewing Tower  
Conventional Builders, Inc  
**RFI 003**

Dear Ms. Delayo,

Century Engineering, LLC (Century) has reviewed the above Request for Information (RFI). We are providing the following responses.

1. Drawing S606 detail 3, can more info be provided for sign brackets? It appears there are 8 brackets, is that correct? Will this be supplied by the owner? Note say by others?
  - a. Only four (4) pairs of sign brackets are to be provided and installed. Detail 3/S606 illustrates one pair supporting the new signposts. The 1-inch diameter Sch. 40 Galvanized Pipe is the only item provided by others for this portion of the work.
2. Drawing S607 detail 10 call for Simpson-Tie C S16SS-R. Can locations be provided?
  - a. Diagonal Bracing is to be used under the Viewing Platform and the approach ramp from Pier 35 to Pier 41. The Simpson-Tie is to be installed to help support the diagonal bracing against the underside of the spans.

Sincerely,  
Century Engineering, LLC

A handwritten signature in blue ink that reads 'Walter J. Hoey, III'.

Walter J. Hoey, III, P.E.  
Senior Engineer

cc: Craig Rhodes (DNREC Fish & Wildlife)  
File: (G:\Projects\175013.00 (DNREC 2017 Engineering OE)\175013.97 Assawoman Wildlife  
Tower\CONST\ConstAdmin\RFI\RFI003\2025-2-6\_RFI003Responses.docx)