

February 18, 2025

TO: ALL OFFERORS

FROM: Amanda Delayo
Bayshore Conservation Planner

SUBJECT: ADDENDUM TO INVITATION TO BID - CONTRACT NO. NAT25001-
ASSAWOMAN

ADDENDUM #6- Bid Due Date Change

All other terms and conditions remain the same.

If you have any questions, please contact me at amanda.delayo@delaware.gov.



February 18, 2025

DNREC Division of Fish and Wildlife
Attn.: Amanda Delayo, Bayshore Conservation Planner
89 Kings Highway
Dover, DE 19901

RE: Assawoman Wildlife Area
Bid Due Date Change

Dear Ms. Delayo,

Century Engineering, LLC (Century) has been informed the specified pipe piles are not readily available for the above project. We are currently researching a substitution pile and recommend postponing the bid date to February 26, 2025 at 10am.

Sincerely,
Century Engineering, LLC

A handwritten signature in blue ink that reads 'Walter J. Hoey, III'.

Walter J. Hoey, III, P.E.
Senior Engineer

Cc: File



February 18, 2025

DNREC Division of Fish and Wildlife
Attn.: Amanda Delayo, Bayshore Conservation Planner
89 Kings Highway
Dover, DE 19901

RE: Assawoman Wildlife Area
Material Change

Dear Ms. Delayo,

Century Engineering, LLC (Century) has researched the availability of the specified steel piles. Based on our discussions with the manufacturer, we approve the use of A252 Pipe Piles constructed of A572 Steel with a minimum yield strength of 50 ksi. These piles are an available, standard product in the size specified on the plans.

Sincerely,
Century Engineering, LLC

A handwritten signature in blue ink that reads 'Walter J. Hoey, III'.

Walter J. Hoey, III, P.E.
Senior Engineer

Cc: Craig Rhodes (DNREC)
File: (G:\Projects\175013.00 (DNREC 2017 Engineering OE)\175013.97 Assawoman Wildlife
Tower\CONST\ConstAdmin\BidChange\2025-2-18_AssawomanMaterialChange.docx)