

## **SECTION 09 65 00**

### **RESILIENT FLOORING**

#### **PART 1 GENERAL**

##### **1.01 SECTION INCLUDES**

- A. Resilient base.

##### **1.02 REFERENCE STANDARDS**

- A. ASTM F1861 - Standard Specification for Resilient Wall Base 2021.

##### **1.03 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Selection Samples: Submit manufacturer's complete set of color samples for Architect's initial selection.

##### **1.04 DELIVERY, STORAGE, AND HANDLING**

- A. Store all materials off of the floor in an acclimatized, weather-tight space.
- B. Protect roll materials from damage by storing on end.

#### **PART 2 PRODUCTS**

##### **2.01 RESILIENT BASE**

- A. Resilient Base: ASTM F1861, Type TS rubber, vulcanized thermoset; style as scheduled.
  - 1. Manufacturers:
    - a. Johnsonite, a Tarkett Company: [www.johnsonite.com/#sle](http://www.johnsonite.com/#sle).
    - b. Roppe Corporation; Contours Profiled Wall Base System: [www.roppe.com/#sle](http://www.roppe.com/#sle).
  - 2. Height: 4 inch (100 mm).
  - 3. Thickness: 0.125 inch (3.2 mm).
  - 4. Finish: Satin.
  - 5. Color: To be selected by Architect from manufacturer's full range.

#### **PART 3 EXECUTION**

##### **3.01 EXAMINATION**

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive resilient base.

##### **3.02 INSTALLATION - GENERAL**

- A. Starting installation constitutes acceptance of subfloor conditions.
- B. Install in accordance with manufacturer's written instructions.

### 3.03 INSTALLATION - RESILIENT BASE

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches (45 mm) between joints.
- B. Miter internal corners. At external corners, use premolded units. At exposed ends, use premolded units.
- C. Install base on solid backing. Bond tightly to wall and floor surfaces.
- D. Scribe and fit to door frames and other interruptions.

### 3.04 CLEANING

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean in accordance with manufacturer's written instructions.

END OF SECTION